



綠建材標章證書

綠建材標章證書字號：GBM0103043(續)

申請廠商：樺森股份有限公司

申請人：王泰恆

廠商地址：臺中市北屯區平心里 19 鄰安順四街 58 號

產品名稱：普通合板

產品型號：HSPC1 (17.5mm, 7 層 F1)、HSPC2 (14.5mm, 7 層 F1)、
HSPC4 (11.5mm, 5 層 F1)、HSPC5 (8.2mm, 5 層 F1)、
HSPC6 (6.2mm, 5 層 F1)、HSPC7 (3.6mm, 3 層 F1)

生產廠址：中國大陸廣東省台山市四九鎮長龍工業區九路 5 號

有效期限：自 112 年 6 月 10 日至 116 年 6 月 9 日止


合格項目：健康綠建材 (E2 逸散)

試驗項目：甲醛 (HCHO) 逸散速率
總揮發性有機物質 (TVOC) 逸散速率

內政部 部長 林石昌

中華民國 1

7 日



試驗報告



報告編號：TB-20-04368

C-20-10624

頁數：1 OF 1

報告日期：109年08月10日

工程名稱：自測
 承包商：----
 委託單位：樺森股份有限公司
 供料廠商：----
 樣品名稱：FI防水合板
 送驗人員：樺森股份有限公司-徐瑞騰
 收件日期：109年07月22日
 試驗日期：109年07月22日~109年08月10日
 備註：1.以上資料由顧客提供(收件及試驗日期除外)

2.除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製
 3.下述報告內容標示#處由顧客提供

試驗結果：

試驗項目	試驗結果		# 規範值	試驗方法
	單邊未剝離長度 / 單邊長度 (mm)			
浸水剝離試驗 (反覆煮沸浸水剝離)	1-1	75.26 / 75.26	試片一側面同一膠合層無剝離部分之長度為50 mm以上	CNS 1349(2014)
	1-2	75.48 / 75.48		
	1-3	75.71 / 75.71		
	1-4	75.20 / 75.20		
	2-1	75.08 / 75.08		
	2-2	75.23 / 75.23		
	2-3	75.10 / 75.10		
	2-4	75.17 / 75.17		
	3-1	75.35 / 75.35		
	3-2	75.28 / 75.28		
	3-3	75.13 / 75.13		
	3-4	75.15 / 75.15		
	4-1	75.18 / 75.18		
	4-2	75.15 / 75.15		
	4-3	75.12 / 75.12		
	4-4	75.18 / 75.18		

註：本試驗報告之試驗地點同實驗室地址

----- oOo -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

國立中興大學農業暨自然資源學院「森林產品檢驗室」
委託檢測服務檢測結果報告書

工程名稱：自測

委託單位：樺森（股）公司

送檢單位：樺森（股）公司

樣品名稱：F1 防白蟻合板

取樣人員 / 單位：徐瑞騰 / 樺森（股）公司

送驗人員 / 單位：徐瑞騰 / 樺森（股）公司

取樣日期：109 年 06 月 08 日

----- 以上資料由送檢人員提供 -----

檢測單位：國立中興大學森林學系

收件日期：109 年 06 月 08 日

檢測日期：109 年 06 月 09 日~109 年 07 月 16 日

檢測負責人：楊德新

檢測樣品：送驗木材

檢測項目及操作條件：

1. 項目 1：參照 CNS 15756 標準（室內試驗）之抗白蟻試驗。



檢測結果：

試體	質量減少率 (%)		白蟻死亡率 (%)	
	平均	最小—最大	平均	最小—最大
試驗組	9.1	8.8—10.8	97.3	90.0—100.0
對照組 (未處理柳杉邊材)	13.1	11.6—14.9	42.3	38.7—46.0

檢測結果說明：

1. 測試試片為廠商所提供樣品隨機取樣裁切所得試片。
2. 本測試結果僅對廠商送測樣品負責。
3. 本報告書需蓋本系系戳始得生效。
4. 本試驗結果僅供參考，不作商業宣傳用途。
5. 其他。

檢測負責人簽章：

教授楊德新

系所主管簽章：

教授兼森林學系系主任吳志鴻

